



O: 604 593 8275 F: 604 593 8276  
 WWW.BCHAZMATINSPECTIONS.CA  
 INFO@BCHAZMATINSPECTIONS.CA  
 #220-19358 96 AVENUE  
 SURREY, BC V4N 4C1

CLIENT ID: Coast BC Hazmat Inspections Inc.  
 SAMPLES SUBMITTED BY: David Furtado  
 LOCATION: 5350 Sunshine Coast Hwy., Sechelt  
 DATE ANALYZED: March 05/2020  
 BCHI ID: 22686

COAST BC HAZMAT INSPECTIONS INC.

## BULK ASBESTOS RESULTS

BCHI SAMPLE ID	CLIENT SAMPLE ID	SAMPLE LOCATION	MATERIAL TYPE	OTHER MATERIAL & AMOUNT	ASBESTOS TYPE & AMOUNT
22686-1	1	102 Rear middle bedroom, Ceiling	Texture coat	Cellulose 1% Non fibrous 99%	Not Detected
			Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22686-2	2	103 Right rear bedroom, Ceiling	Texture coat	Cellulose 1% Non fibrous 99%	Not Detected
			Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22686-3	3	105 Kitchen, Ceiling	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22686-4	4	102 Right middle bedroom, West wall	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22686-5	5	103 Right rear bedroom, Closet	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22686-6	6	104 Living room, East wall	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22686-7	7	105 Kitchen, North wall	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22686-8	8	106 Sundeck room, South wall	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22686-9	9	101 Bathroom, Floor, First layer	Vinyl sheet, Vinyl top	Non fibrous>99%	Not Detected
			Vinyl sheet, Backing	Cellulose 30% Non fibrous 70%	Not Detected
22686-10	10	101 Bathroom, Floor, Second layer	Peel & Stick, Vinyl tile	Non fibrous>99%	Not Detected
22686-11	11	102 Rear middle bedroom, Floor	Vinyl sheet, Vinyl top	Non fibrous>99%	Not Detected



COAST BC HAZMAT INSPECTIONS INC.

## BULK ASBESTOS RESULTS

O: 604 593 8275 F: 604 593 8276

WWW.BCHAZMATINSPECTIONS.CA

INFO@BCHAZMATINSPECTIONS.CA

#220-19358 96 AVENUE

SURREY, BC V4N 4C1

CLIENT ID: Coast BC Hazmat Inspections Inc.

SAMPLES SUBMITTED BY: David Furtado

LOCATION: 5350 Sunshine Coast Hwy., Sechelt

DATE ANALYZED: March 05/2020

BCHI ID: 22686

BCHI SAMPLE ID	CLIENT SAMPLE ID	SAMPLE LOCATION	MATERIAL TYPE	OTHER MATERIAL & AMOUNT	ASBESTOS TYPE & AMOUNT
			Vinyl sheet, Backing	Non fibrous 70%	<b>Chrysotile 30%</b>
22686-12	12	105 Kitchen, Floor, First layer	Vinyl sheet, Vinyl top	Non fibrous>99%	Not Detected
			Vinyl sheet, Backing	Cellulose 30% Non fibrous 70%	Not Detected
22686-13	13	105 Kitchen, Floor, Second layer	Peel & Stick, Vinyl tile	Non fibrous>99%	Not Detected
22686-14	14	105 Kitchen, Floor, Third layer	Vinyl sheet, Vinyl top	Non fibrous>99%	Not Detected
			Vinyl sheet, Backing	Non fibrous 70%	<b>Chrysotile 30%</b>
22686-15	15	102 Rear middle bedroom, Window	Putty	Non fibrous 99%	<b>Chrysotile 1%</b>
22686-16	16	104 Living room, Window	Putty	Non fibrous 99%	<b>Chrysotile 1%</b>
22686-17	17	105 Kitchen, Window	Putty	Non fibrous 99%	<b>Chrysotile 1%</b>
22686-18	18	Exterior house, Roof	Asphalt shingle	Fiberglass 30% Non fibrous 70%	Not Detected
22686-19	19	Exterior house, Roof	Asphalt shingle	Fiberglass 30% Non fibrous 70%	Not Detected

Analytical Method: NIOSH 9002 Analyst: Baraa Habash

Coast BC Hazmat Inspections Inc. participates in the AIHA

bulk asbestos proficiency analytical testing program, participant number 223436