



COAST BC HAZMAT INSPECTIONS INC.

O: 604 593 8275 F: 604 593 8275
 WWW.BCHAZMATINSPECTIVE.COM
 INFO@BCHAZMATINSPECTIVE.COM
 #220-19358 96 AVENUE
 SURREY, BC V4N 4C1

CLIENT ID: Coast BC Hazmat Inspections Inc.
 SAMPLES SUBMITTED BY: David Furtado
 LOCATION: 5530 Sxwelap Ave (Old Family Center)
 DATE ANALYZED: March 05/2020
 BCHI ID: 22673-1

XRF LEAD RESULTS

BCHI SAMPLE ID	CLIENT SAMPLE ID	SAMPLE LOCATION	MATERIAL TYPE	COLOR	LEAD CONCENTRATION (PPM)	Variance +/-	Result Positive/Negative
22673-1-1	1	102 Kitchen, North wall	Paint chip	White	42	17	Negative
22673-1-2	2	105 Room, North wall	Paint chip	White	42	17	Negative
22673-1-3	3	107 Bathroom, East wall	Paint chip	Blue	41	16	Negative
22673-1-4	4	108 Bathroom, East wall	Paint chip	Yellow	41	15	Negative
22673-1-5	5	Exterior house, South wall	Paint chip	Yellow	40	15	Negative
22673-1-6	6	Exterior house, South wall	Paint chip	Brown	40	15	Negative

Equipment Used: Bruker Titan 500 XRF Analyzer Analyst: Baraa Habash

Health Canada states samples ≥ 90 PPM to be Lead Containing