



COAST BC HAZMAT INSPECTIONS INC.

XRF LEAD RESULTS

O: 604 593 8275 F: 604 593 8275
 WWW.BCHAZMATINSPECTIVE.COM
 INFO@BCHAZMATINSPECTIVE.COM
 #220-19358 96 AVENUE
 SURREY, BC V4N 4C1

CLIENT ID: Coast BC Hazmat Inspections Inc.
 SAMPLES SUBMITTED BY: David Furtado
 LOCATION: 5350 Sunshine Coast Hwy., Sechelt
 DATE ANALYZED: March 05/2020
 BCHI ID: 22686-1

BCHI SAMPLE ID	CLIENT SAMPLE ID	SAMPLE LOCATION	MATERIAL TYPE	COLOR	LEAD CONCENTRATION (PPM)	Variance +/-	Result Positive/Negative
22686-1-1	1	101 Bathroom, East wall	Paint chip	Yellow	47	12	Negative
22686-1-2	2	103 Right rear bedroom, North wall	Paint chip	Grey	42	17	Negative
22686-1-3	3	106 Sun room, North wall	Paint chip	White	41	15	Negative
22686-1-4	4	Exterior house, East wall	Paint chip	Yellow	52	13	Negative
22686-1-5	5	Exterior house, West wall	Paint chip	Yellow	53	17	Negative

Equipment Used: Bruker Titan 500 XRF Analyzer Analyst: Baraa Habash

Health Canada states samples ≥ 90 PPM to be Lead Containing