



COAST BC HAZMAT INSPECTIONS INC.

O: 604 593 8275 F: 604 593 8275  
WWW.BCHAZMATINSPECTIVE.COM  
INFO@BCHAZMATINSPECTIVE.COM  
#220-19358 96 AVENUE  
SURREY, BC V4N 4C1

CLIENT ID: Coast BC Hazmat Inspections Inc.  
SAMPLES SUBMITTED BY: David Furtado  
LOCATION: 5495 Skupa Ave (Community Garder Building)  
DATE ANALYZED: March 5/2020  
BCHI ID: 22671-2

## XRF LEAD RESULTS

BCHI SAMPLE ID	CLIENT SAMPLE ID	SAMPLE LOCATION	MATERIAL TYPE	COLOR	LEAD CONCENTRATION (PPM)	Variance +/-	Result Positive/Negative
22671-2-1	1	103 Bathroom, North wall	Paint chip	Yellow	42	17	Negative
22671-2-2	2	104 Entry, North wall	Paint chip	White	43	15	Negative
22671-2-3	3	105 Kitchen, East wall	Paint chip	Yellow	41	15	Negative
22671-2-4	4	106 Storage room, West wall	Paint chip	White	41	15	Negative
22671-2-5	5	Exterior house, South wall	Paint chip	White	42	17	Negative

Equipment Used: Bruker Titan 500 XRF Analyzer Analyst: Baraa Habash

Health Canada states samples  $\geq 90$  PPM to be Lead Containing