



O: 604 593 8275 F: 604 593 8276
 WWW.BCHAZMATINSPECTIONS.CA
 INFO@BCHAZMATINSPECTIONS.CA

CLIENT ID: Coast BC Hazmat Inspections Inc.
 SAMPLES SUBMITTED BY: David Furtado
 LOCATION: 5349 Sunshine Coast Hwy., Sechelt

#220-19358 96 AVENUE

DATE ANALYZED: March 05/2020

SURREY, BC V4N 4C1

BCHI ID: 22674

COAST BC HAZMAT INSPECTIONS INC.

BULK ASBESTOS RESULTS

BCHI SAMPLE ID	CLIENT SAMPLE ID	SAMPLE LOCATION	MATERIAL TYPE	OTHER MATERIAL & AMOUNT	ASBESTOS TYPE & AMOUNT
22674-1	1	202 Kitchen, Ceiling	Texture coat	Non fibrous 97%	Chrysotile 3%
			Filler compound	Non fibrous 97%	Chrysotile 3%
22674-2	2	204 Living room, Ceiling	Texture coat	Non fibrous 97%	Chrysotile 3%
22674-3	3	208 Left rear bedroom, Ceiling	Texture coat	Non fibrous 97%	Chrysotile 3%
22674-4	4	102 Entry, Ceiling	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22674-5	5	102 Entry, South wall	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22674-6	6	102 Entry, South wall	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
			Mesh	Fiberglass>99%	Not Detected
22674-7	7	203 Dining room, East all	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
22674-8	8	204 Living room, East wall	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
			Mesh	Fiberglass>99%	Not Detected
22674-9	9	207 Left middle bedroom, South wall	Filler compound	Cellulose 2% Non fibrous 98%	Not Detected
			Mesh	Fiberglass>99%	Not Detected
22674-10	10	204 Living room, Fireplace	Brick mortar	Non fibrous>99%	Not Detected



COAST BC HAZMAT INSPECTIONS INC.

BULK ASBESTOS RESULTS

O: 604 593 8275 F: 604 593 8276
 WWW.BCHAZMATINSPECTIONS.CA
 INFO@BCHAZMATINSPECTIONS.CA

#220-19358 96 AVENUE

SURREY, BC V4N 4C1

CLIENT ID: Coast BC Hazmat Inspections Inc.

SAMPLES SUBMITTED BY: David Furtado

LOCATION: 5349 Sunshine Coast Hwy., Sechelt

DATE ANALYZED: March 05/2020

BCHI ID: 22674

BCHI SAMPLE ID	CLIENT SAMPLE ID	SAMPLE LOCATION	MATERIAL TYPE	OTHER MATERIAL & AMOUNT	ASBESTOS TYPE & AMOUNT
22674-11	11	204 Living room, Fireplace	CT Grout	Non fibrous>99%	Not Detected
22674-12	12	204 Living room, Fireplace	CT Mortar	Non fibrous>99%	Not Detected
22674-13	13	202 Kitchen, Floor	Vinyl sheet, Vinyl top	Non fibrous>99%	Not Detected
			Vinyl sheet, Backing	Cellulose 30% Non fibrous 70%	Not Detected
22674-14	14	203 Dining room, Floor	Vinyl sheet, Vinyl top	Non fibrous>99%	Not Detected
			Vinyl sheet, Backing	Cellulose 30% Non fibrous 70%	Not Detected
22674-15	15	205 Entry, Floor	Vinyl sheet, Vinyl top	Non fibrous>99%	Not Detected
			Vinyl sheet, Backing	Non fibrous 70%	Chrysotile 30%
22674-16	16	206 Bathroom, Floor	Vinyl sheet, Vinyl top	Non fibrous>99%	Not Detected
			Vinyl sheet, Backing	Non fibrous 70%	Chrysotile 30%
22674-17	17	207 Left middle bedroom, Floor	Vinyl sheet, Vinyl top	Non fibrous>99%	Not Detected
			Vinyl sheet, Backing	Cellulose 30% Non fibrous 70%	Not Detected
22674-18	18	102 Entry, Window	Putty	Non fibrous 99%	Chrysotile 1%



COAST BC HAZMAT INSPECTIONS INC.

BULK ASBESTOS RESULTS

O: 604 593 8275 F: 604 593 8276
 WWW.BCHAZMATINSPECTIONS.CA
 INFO@BCHAZMATINSPECTIONS.CA

#220-19358 96 AVENUE
 SURREY, BC V4N 4C1

CLIENT ID: Coast BC Hazmat Inspections Inc.
 SAMPLES SUBMITTED BY: David Furtado
 LOCATION: 5349 Sunshine Coast Hwy., Sechelt
 DATE ANALYZED: March 05/2020
 BCHI ID: 22674

BCHI SAMPLE ID	CLIENT SAMPLE ID	SAMPLE LOCATION	MATERIAL TYPE	OTHER MATERIAL & AMOUNT	ASBESTOS TYPE & AMOUNT
22674-19	19	102 Entry, Window	Putty	Non fibrous 99%	Chrysotile 1%
22674-20	20	102 Entry, Window	Putty	Non fibrous 99%	Chrysotile 1%
22674-21	21	208 Left rear bedroom, Window	Putty	Non fibrous 99%	Chrysotile 1%
22674-22	22	209 Left rear bedroom, Window	Putty	Non fibrous 99%	Chrysotile 1%
22674-23	23	209 Left rear bedroom, Window	Putty	Non fibrous 99%	Chrysotile 1%
22674-24	24	Exterior house, Roof	Asphalt shingle	Fiberglass 30% Non fibrous 70%	Not Detected
22674-25	25	Exterior house, Roof	Asphalt shingle	Fiberglass 30% Non fibrous 70%	Not Detected

Analytical Method: NIOSH 9002 Analyst: Baraa Habash

Coast BC Hazmat Inspections Inc. participates in the AIHA

bulk asbestos proficiency analytical testing program, participant number 223436