



COAST BC HAZMAT INSPECTIONS INC.

O: 604 593 8275 F: 604 593 8275
 WWW.BCHAZMATINSPECTIVE.COM
 INFO@BCHAZMATINSPECTIVE.COM
 #220-19358 96 AVENUE
 SURREY, BC V4N 4C1

CLIENT ID: Coast BC Hazmat Inspections Inc.
 SAMPLES SUBMITTED BY: David Furtado
 LOCATION: 5349 Sunshine Coast Hwy., Sechelt
 DATE ANALYZED: March 05/2020
 BCHI ID: 22674-1

XRF LEAD RESULTS

BCHI SAMPLE ID	CLIENT SAMPLE ID	SAMPLE LOCATION	MATERIAL TYPE	COLOR	LEAD CONCENTRATION (PPM)	Variance +/-	Result Positive/Negative
22674-1-1	1	Exterior house, North wall	Paint chip	Blue	128	40	Positive
22674-1-2	2	Exterior house, East wall	Paint chip	Blue	131	41	Positive
22674-1-3	3	204 Living room, East wall	Paint chip	White	42	17	Negative
22674-1-4	4	205 Entry, West wall	Paint chip	White	42	17	Negative
22674-1-5	5	207 Left middle bedroom, East wall	Paint chip	Pink	41	15	Negative
22674-1-6	6	207 Left middle bedroom, South wall	Paint chip	Green	41	15	Negative
22674-1-7	7	209 Sun room, West wall	Paint chip	Yellow	41	15	Negative

Equipment Used: Bruker Titan 500 XRF Analyzer Analyst: Baraa Habash

Health Canada states samples ≥ 90 PPM to be Lead Containing